TECHNICAL INFORMATION

TI-TS-0004v100EN

UPDATE SYSTEM PROGRAM By USB Memory

Type Software version Required options Use Date Version Author Revised Approved Languages

To update the System Program by USB memory in TS.

Please follow the following steps:

- 1- Open the related TS screen program with VSFT6
- 2- Plug in a USB stick in the PC.
- 3- Go to the "FILE" menu and press the icon "Storage Manager"



4- Select the unit where the USB is plugged in.



5- Press the icon "Write to storage"



6- Select "Write Data Being Edited, Automatic Upload and System Program Transfer"

Write to storage					
👿 Write Data Being Edited					
Path of Screen Data File to Be Converted					
Open					
DSP0000.BIN File Comment					
 Automatic Upload System Program Transfer Run arter System Program Transfer Transfer OS 					
Do Not Overwrite Port No. Table/FROM Backup Area Write OS OK Cancel					

- 7- Plug in the USB stick the the TS unit.
- 8- Set to ON the DIP switch nº1 on the backside.

The TS series is equipped with DIP switches 1 to 8. When setting the DIP switches, turn the power off.



- 9- Power ON the TS.
- 10- The TS will be updated automatically. (Screen Program + System Program)
- 11- Set to OFF the DIP switch nº1 on the backside.

Document history.

Version	Changes applied	Date	Written	Revised	Approved